



APPROVED

FIRE SERVICE CONNECTIONS

This certificate is issued for the following equipment:

Figure No.	Component Description	Nominal Size (Inlet x Outlet, in.)
10	90° Sidewalk Siamese	2-1/2 x 2-1/2 x 4, 6
11	Straightway Siamese	2-1/2 x 2-1/2 x 4
12	Straightway Siamese	2-1/2 x 2-1/2 x 4, 6
15	Sidewalk Siamese (Female Connections)	2-1/2 x 2-1/2 x 4, 5, 6
16	Sidewalk Siamese (Male connections)	2-1/2 x 2-1/2 x 4, 5, 6
155	Wall Siamese (with Sill Cock)	2-1/2 x 2-1/2 x 4, 5, 6
156	Wall Siamese (without Sill Cock)	2-1/2 x 2-1/2 x 4, 5, 6
165	Flush Siamese (with Sill Cock)	2-1/2 x 2-1/2 x 4, 5, 6
166	Flush Siamese (without Sill Cock)	2-1/2 x 2-1/2 x 4, 5, 6

Manufactured by: ELKHART BRASS MFG CO INC
1302 WEST BEARDSLEY AVE
ELKHART, INDIANA 46514

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard Class Number 1530

Project Identifier: 0V1H9.AH

Date of Approval: May 2, 2002



Member of the FM Global Group

Richard B. Dunne

Manager - Hydraulics Group, FM Approvals

Date

April 23, 2007