



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 162.027/14/0

Expires: 18 October 2017

COMBINATION FIRE HOSE NOZZLE

ELKHART BRASS MANUFACTURING COMPANY
1302 WEST BEARDSLEY AVENUE
ELKHART INDIANA 46514

Elkhart Model SFL-CG-95, size 1-1/2 inch, 95 gpm combination fire hose nozzle.

Identifying Data: FM Approval Report under Project Number 3047897, and Elkhart drawing labeled D-SFL-CG-95, Rev. REL.

The SFL-CG-95 nozzle meets the requirements of NFPA 1964, Standard for Spray Nozzles.

FM follow-up program in effect.

Valid for nozzles manufactured at the facility at the above address.


Extends Certificate of Approval No. 162.027/14/0 dated 18 October 2007.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 18th DAY OF
OCTOBER 2012, AT WASHINGTON D.C.


K. J. HEINZ
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT